

FIRE FLOW SUBMITTAL

Example of Fire Flow Report format

NOTES:

- Coordinate Fire Flow test with Steven Wallace at Marsh USA, Atlanta GA
- Report must be dated no more than 6 months prior to Publix issuing it's drawings
- Fire flow calculations should use a discharge coefficient of **0.80**, as called for in the Fire Protection Water Supply section of the Publix Site Development Manual.

PREPARED BY:

DATE



SR 92

THOMPSON ROAD

SOUTH FULTON PARKWAY

PUBLIX

PROP. FH

200 LF 12" DP PROP. FH

55 LF 6" DP

PARKING LOT

FRICTION LOSS

EXISTING 12" PIPE	=	709 LF
NEW 8" PIPE TO PARALLEL SYSTEM	=	116 LF
PARALLEL SYSTEM SHORT LEG	=	201.5 LF
PARALLEL SYSTEM LONG LEG	=	1741.5 LF
FROM PARALLEL SYSTEM TO RISER	=	63 LF

CALCULATION OF EQUIVALENT LENTGH FOR FITTINGS FOR EXISTING 12" PIPE

<u>FITTINGS</u>	<u>QUANTITY</u>	<u>EQ. LENGTH</u>	<u>UNIT</u>
12X12X8 TEE	1	49.00	LF
12" 45° ELBOW	4	62.00	LF

TOTAL LENGTH	111.00	LF
---------------------	---------------	-----------

TOTAL LENGTH OF EXISTING 12" PIPE	820.00	LF
--	---------------	-----------

CALCULATION OF EQUIVALENT LENTGH FOR FITTINGS FOR NEW 8" PIPE FROM FENCE ROAD TO PARALLEL SYSTEM

<u>FITTINGS</u>	<u>QUANTITY</u>	<u>EQ. LENGTH</u>	<u>UNIT</u>
8X8X8 TEE	1	42.00	LF
8" GATE VALVE	1	4.50	LF
8" CHK VALVE	1	52.00	LF
8" 45° ELBOW	1	11.00	LF

TOTAL LENGTH	109.50	LF
---------------------	---------------	-----------

TOTAL LENGTH OF NEW 8" PIPE	225.00	LF
------------------------------------	---------------	-----------

CALCULATION OF EQUIVALENT LENTGH FOR FITTINGS FOR PARALLEL SYSTEM SHORT LEG

<u>FITTINGS</u>	<u>QUANTITY</u>	<u>EQ. LENGTH</u>	<u>UNIT</u>
8X8X8 TEE	1	42.00	LF
8X8X6 TEE	1	45.50	LF

TOTAL LENGTH	87.50	LF
---------------------	--------------	-----------

TOTAL LENGTH OF PARALLEL SYSTEM SHORT LEG	289.00	LF
--	---------------	-----------

CALCULATION OF EQUIVALENT LENGTH FOR FITTINGS FOR PARALLEL SYSTEM LONG LEG

FITTINGS	QUANTITY	EQ. LENGTH	UNIT
8X8X8 TEE	2	84.00	LF
8X8X6 TEE	6	273.00	LF
8" 90° ELBOW	1	21.00	LF
8" 45° ELBOW	6	66.00	LF
8" 22.50° ELBOW	2	6.00	LF

TOTAL LENGTH	450.00	LF
---------------------	---------------	-----------

TOTAL LENGTH OF PARALLEL SYSTEM LONG LEG	2191.50	LF
---	----------------	-----------

CALCULATION OF FRICTION LOSS PER LF OF PIPE

FRICTION FACTOR, C = 100.00 FOR EXIST. PIPE
 140.00 FOR NEW PIPE
 GPM = 1248 GPM
 Diameter, d (inch) = 8.00 FOR 8" PIPE
 6.00 FOR 6" PIPE
 12.00 FOR 12" PIPE

CALCULATIONS

HAZEN WILLIAMS EQUATION

FLOW COMPUTATIONS

NODE	LENGTH L (ft)	FLOW		PIPE DIAMETER D (in)	LOSS h (ft)	PRESSURE LOSS PSI	NOTES
		C	Q (gpm)				
1	820	100	1248	12	5.1	2.22	
2	225	140	1248	8	5.4	2.35	
3	289	140	933	8	4.1	1.76	PARALLEL SYSTEM PARALLEL SYSTEM
4	2191.5	140	315	8	4.1	1.76	
5	63	140	1248	8	1.5	0.66	
TOTAL LOSS					10.1	8.99	

TYPE OF EQUIPMENT	PRESSURE LOSS	UNIT
FOR EXIST. 12" PIPE:	2.22	PSI
FOR NEW 8" PIPE"	4.77	PSI
8" DBL DRT CHK BFP (BASED ON WATTS MODEL 757 NDCDA)	4.50	PSI
TOTAL:	11.49	PSI

HYDRANT TO RISER PRESSURE CALCULATION

ELEVATION

AT HYDRANT = 922 FT
AT RISER = 936 FT
EL. DIFFERENCE = -14.00 FT

PRESSURE AT HYDRANT

STATIC = 105 PSI
RESIDUAL = 100 PSI

PRESSURE AT RISER

STATIC = 105-14.0*0.433
= 98.94 PSI

RESIDUAL = 100-14.0*0.433-11.49
= 82.45 PSI

PUBLIC REQUIREMENTS AT RISER

1100 GPM AT 35 PSI

FLOW @ REQUIRED PRESSURE (35 PSI)

$$Q_R = Q_F \times \frac{H_R^{0.54}}{H_F^{0.54}} \quad Q_F = 1248 \text{ GPM}$$

$$Q_R = 1248 \times \frac{63.94^{0.54}}{16.49^{0.54}} \quad H_R = 98.94 - 35 = 63.94 \text{ PSI}$$

$$H_F = 98.94 - 82.45 = 16.49 \text{ PSI}$$

$$Q_R = 2594.37 > 1100 \text{ GPM}$$

PRESSURE @ REQUIRED FLOW (1100 GPM)

$$H_R^{0.54} = \frac{Q_R \times H_F^{0.54}}{Q_F} \quad Q_R = 1100.00 \text{ GPM}$$

$$H_R^{0.54} = \frac{1100 \times 16.49^{0.54}}{1248} \quad H_R = 98.94 - X$$

$$H_R = 13.05 \quad Q_F = 1248 \text{ GPM}$$

$$13.05 = 98.94 - X$$

$$X = 85.89 > 35 \text{ PSI}$$

PROJECT: PUBLIC 45.3 LOCATION: FULTON COUNTY WATER SOURCE: EXIST. 12" MAIN

GEORGIA

HYDRANT ELEVATION: 92.2 FT
 B.O.R. ELEVATION: 93.6 FT
 STATIC PRESSURE: 105 PSI
 RESIDUAL PRESSURE: 82.45 PSI
 RESIDUAL FLOW: 1248 GPM

DATE: 9/01/06 BY: Patrick D.

HYDRANT

RISER

120
110
100
90
80
70
60
50
40
30
20
10

PRESSURE - PSI

LOADING DOCK AREA
621 GPM @ 39 PSI

RECEIVING AREA
1818 GPM @ 47 PSI

SALES AREA
739 GPM @ 28 PSI

100 200 300 400 500 600 700 800 900

0.185 FLOW - GPM

APPROVED: _____ DATE: _____
 PUBLIC ENTER MARKETS, INC.
 CHECKED BY: _____
 DISPOSITION: _____
 APPROVED AS NOTED
 DISAPPROVED - REASON: _____
 NOT CHECKED BY PUBLIC: _____
 Follow plans and specifications
 no substitutions allowed
 CONTRACTOR SHALL MAINTAIN SUFFICIENT AND GENERAL CONTRIBUTION
 TO THE PROJECT AND SHALL BE RESPONSIBLE FOR ALL COSTS OF THE PROJECT
 AND ALL OTHER REQUIREMENTS OF THE WATERWORKS DEPARTMENT
 WATER 205 Department Approval Use Water Person to Administration

